

DEPARTMENT OF INDUSTRIAL RELATIONS  
**DIVISION OF OCCUPATIONAL SAFETY & HEALTH**  
**RESEARCH & STANDARDS DEVELOPMENT UNIT**

1515 CLAY ST. SUITE 1901  
OAKLAND, CA. 94102  
(510) 286-7013  
FAX: (510) 286-7040



February 26, 2007

Georges Boyazis, President  
Innovative Petroleum Products LLC  
P.O. Box 1102  
St. Augustine, Florida 32085-1102

**Re: APPROVAL – Marley Petroplas Fluorinated High-Density Polyethylene (HDPE)  
Piping Systems**

Dear Mr. Boyazis:

This is in response to your letter dated February 2, 2007, requesting Division evaluation and approval of the above piping system. The Petroplas Piping system with its associated Frialen electro-fusion fittings is specifically designed for underground use for conveying motor vehicle fuels, concentrated fuels, high-blend fuels, aviation and marine fuels.

In June 2006 Underwriter's Lab tested and determined this system to comply with UL 971- Standard for Non-Metallic Underground Piping for Flammable Liquids, First Edition Dated 10-30-1995. It is approved for UL listing.

The California Division of Occupational Safety and Health of the Department of Industrial Relations is the only agency responsible for determining whether any gasoline vapor control system or component creates a safety hazard other than a fire hazard. If the Division determines that a system or component creates a safety hazard, other than a fire hazard, that system or component may not be used until the Division has certified that the system or component does not create a hazard (California Health and Safety Code, Section 41957).

Based on the information submitted, the Division has concluded that the installation of the Marley Petroplas Fluorinated High-Density Polyethylene (HDPE) Piping Systems does not appear to create a safety hazard as defined in Health and Safety Code Section 41957. This acceptance is conditional on installation and use in accordance with manufacturer's recommendations.

Georges Boyazis

Page 2

February 26, 2007

If you have any question about this matter, please contact me at (510) 286-7013.

Sincerely,



Larry McCune, PE  
Principal Safety Engineer  
Division of Occupational Safety and Health

cc: George Lew, Chief (w/o Encl.)  
Engineering and Certification Branch  
Monitoring and Laboratory Division  
California Air Resources Board (CARB)  
PO Box 2815  
Sacramento, CA 95812