



VAPOR RECOVERY CERTIFICATION

Certification No. GVRC
005:060:001
Page 1 of 1

GASOLINE VAPOR RECOVERY SYSTEM PIPING

LISTEE— Innovative Petroleum Products (Marley), 1721 Franklin Rd., Springfield, Jacksonville, FL. 32206
P.O. Box 1102, St. Augustine, FL. 32085-1102

DESIGN— Underground Piping for Flammable Liquids – Flexible and Rigid Type Piping for use as Integral Primary/Secondary Pipe System (PS) piping for underground fuel transfer applications such as gas stations for motor vehicle (MV) fuels, concentrated fuels (CF), high blend fuels (HB) and aviation and marine fuels (A&M); and Flexible and Rigid Type Piping for use as normal vent (NV) piping for underground venting applications such as gas stations for motor vehicle fuels, concentrated fuels, high blend fuels and aviation and marine fuels, consisting of pipe designated "Petroplas SF2P, fusion fittings designated "Frialon" and termination fittings designated "Petroplas".

The primary portion of the integral primary/secondary pipe system and the vent pipe consists of a single layer polyethylene pipe. The secondary portion of the integral primary/secondary pipe system consists of a single layer of polyethylene pipe with internal longitudinal standoff ribs.

APPLICATION— For Stage I and II Systems

INSTALLATION—To be installed in accordance with manufacturer's instructions and all applicable codes.

MARKING— Type of pipe and fittings: UGN = Underground Nonmetallic, PS = Integral Primary/Secondary, NV = Normal Vent, VR = Vapor Recovery; "For MV, HB, CT and A&M Fuels, (Control #) and U.L. Label

CERTIFICATION—Certified for use with Stage I or II Vapor Recovery Systems where full or self service is provided.

This certification is made pursuant to the authority granted to the California State Fire Marshal as contained in Sections 41955 through 41960 inclusive, California Health and Safety Code. The certification is based upon independent tests or other technical data submitted by the applicant. CSFM staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This certification is not an endorsement or recommendation for the use of the item(s) specified. This certification should not be used to verify correct operational requirements or installation criteria.

ISSUED: FEBRUARY 15, 2007

AUTHORIZED BY:

Ken Vollenweider
Senior Deputy State Fire Marshal
Vapor Recovery Program