



Certificate of Compliance

Issued to : Friatec Plasmec (Pty) Ltd, South Africa

Item : Underground petroleum pipework for positive pressure and suction delivery fuel lines, also suitable for fill pipes, vent lines, vapour recovery and secondary containments.

Type Reference : Petroplas SF2P™ Generation 2, 63 mm diameter pipe for use with designated Frialen electrofusion welding connections.

This is to certify that samples of the product defined above have been tested by ERA Technology Ltd and found to comply with the following requirements :

Institute of Petroleum Performance Specification for Underground Pipework Systems at Petrol Filling Stations


ISBN 0 85293 164 6, November 1995.

Full details are given in ERA report number : 2000-0115

Note 1: The minimum bend radius is declared as 30 x diameter.


Note 2: The pipes shall be marked in accordance with the Institute of Petroleum performance specification.

Certificate prepared by :



J H Greenwood
Materials Testing Consultant
Materials Testing Department

Certificate approved by :



T D Johnson
Manager
Plant & Power Engineering Division

Certificate number : BC63/0115/2000/001

Dated : 23 March 2000

**ERA Technology Ltd, Cleeve Road, Leatherhead, Surrey KT22 7SA
ERA Technology Inc, 16203 Park Row, Suite 175, Houston, Texas 77084, USA**