



Certificate of Compliance

Issued to : Friatec Plasmec (Pty) Ltd, South Africa

Item : Underground petroleum pipework for positive pressure and suction delivery fuel lines, also suitable for fill pipes, vent lines, vapour recovery and secondary containments.

Type Reference : Petroplas SF2P™ 50 mm, 63 mm and 110 mm diameter pipe for use with designated Frialen electrofusion welding connections.


This is to certify that samples of the product defined above have been tested by ERA Technology Ltd and found to comply with the following requirements :

Shell International Petroleum Company Limited Pipework Performance Specification and /supplier Evaluation, Version 2, March 1988

Full details are given in ERA report number : 98-1010


Note: The minimum bend radius is declared as 30 x diameter

Certificate prepared by :



J H Greenwood
Technical Executive
Materials Testing Department

Certificate approved by :



P R McCarthy
Manager
Materials Testing Department

Certificate number: BC63/1010/98/002

dated: 14 December 1998

ERA Technology Ltd, Cleeve Road, Leatherhead, Surrey KT22 7SA
ERA Technology Ltd, Unit 8 Woodfieldside Business Park, Pontllanfraith, Blackwood, Gwent NP2 2DG
ERA Technology Inc, 16203 Park Row, Suite 175, Houston, Texas 77084, USA
ERA Technology (Asia) Pte Ltd, 83 Science Park Drive, #03-02A, The Curie, Singapore 0511